

Metals/Metalloids ^A	g/m ³	Dependency	Reference
Aluminium	0.62 ^B	Hardness, pH, Dissolved Organic Carbon	USEPA (2018)
Arsenic	0.013	As arsenic (V)	ANZECC (2000) ^C
Boron	0.94	NA	ANZECC (2018) ^C
Cadmium	0.0002 ^D	Hardness	ANZECC (2000) ^C
Chromium	0.0033 ^D	Hardness, as chromium (III)	ANZECC (2000) ^C
Copper	0.0039 ^E	Hardness, pH, Dissolved Organic Carbon	USEPA (2007)
Iron	1.0	As total fraction	USEPA (1986)
Lead	0.0034 ^D	Hardness	ANZECC (2000) ^C
Manganese	1.9	NA	ANZECC (2000) ^C
Nickel	0.011 ^D	Hardness	ANZECC (2000) ^C
Zinc	0.008 ^D	Hardness	ANZECC (2000) ^C

^A dissolved fraction, unless stated

^B at hardness = 25 g/m³, pH = 7.0, Dissolved Organic Carbon = 1.0 g/m³

^C 95%-ile trigger value

^D at hardness = 30 g/m³

^E at hardness = 25 g/m³, pH = 7.0, Dissolved Organic Carbon = 2.0 g/m³